



INSURANCE SERVICES OFFICE, INC.

4B Eves Drive, Suite 200, Marlton, New Jersey 08053 (856) 985-5600 FAX (856) 985-6491

January 13, 2009

Deputy Chief Mike Linkins
Polk County Fire/Rescue
PO Box 1458
Bartow, FL 1458

RE: Polk County Fire District, Polk County, FL

Dear Deputy Chief Linkins,

Thank you for the information you sent us regarding Fire Station 27, located at 101 Adventure Ct., Davenport, FL 33837.

We are now recognizing this fire station and Class 5/9 now applies. Class 5 applies to properties that are within 1000 feet of a recognized fire hydrant, within 5 road miles of a responding fire station and with a needed fire flow of 3500 GPM or less. Class 9 applies to properties beyond 1000 feet from a fire hydrant but within 5 road miles of a responding fire station. The public and private fire suppression capability for properties with a needed fire flow greater than 3500 GPM is individually evaluated and may vary from the community. All others are Class 10. This station will appear in our mapping beginning March 1, 2009.

If you have any questions, feel free to contact me. I would be more than happy to assist you any way I can.

Sincerely yours,

Kevin Gimeno

Kevin Gimeno
Community Mitigation Analyst
Tel. 856-985-5600 ext. 430
Fax 856-985-6491
E-mail kgimeno@iso.com